

# Navrh otopnych teles firmy

Akce : ZD Ostas - Zdar nad Metuji - budova B  
Datum : 23. 8.2022

Teplota topne vody - privodni : 60.0 oC  
vratne : 45.0 oC  
Procento vykonu pro navrh teles : 100.0

Vypis pro okruh c. 1

Mistnost cislo popis	Soustava teplota oC oC/oC	Otopne teleso --	vodni tepelny		
			delka mm	objem dm3	vykon W
1.01 schodiste	20 60/45	22-090110-60-VK	1100	9.2	1390
1.12 umyvarena	20 60/45	21-090070-60-VK	700	5.8	671
2.01 chodba	20 60/45	22-060200-60-VK	2000	11.6	1853
2.02 kaneelar	20 60/45	21-060140-60-VK	1400	8.1	997
2.03 kancelar	20 60/45	11-060160-60-VK	1600	5.0	894
2.04 kancelar	20 60/45	22-060160-60-VK	1600	9.3	1482
2.05 archiv	15 60/45	21-060120-60-VK	1200	7.0	1040
2.05 archiv	15 60/45	21-060140-60-VK	1400	8.1	1213
2.07 kuchynka	20 60/45	22-060050-60-VK	500	2.9	464
2.08 sklad	15 60/45	21-060100-60-VK	1000	5.8	867
2.08 sklad	15 60/45	21-060100-60-VK	1000	5.8	867
2.08 sklad	15 60/45	21-060090-60-VK	900	5.2	780
2.09 sklad	15 60/45	21-060110-60-VK	1100	6.4	953
2.09 sklad	15 60/45	21-060100-60-VK	1000	5.8	867
1.13 opravna stroju	18 60/45	22-090140-60-VK	1400	11.8	1924
1.13 opravna stroju	18 60/45	22-090140-60-VK	1400	11.8	1924
1.13 opravna stroju	18 60/45	22-090140-60-VK	1400	11.8	1924
1.13 opravna stroju	18 60/45	22-090140-60-VK	1400	11.8	1924
1.13 opravna stroju	18 60/45	22-090140-60-VK	1400	11.8	1924
1.13 opravna stroju	18 60/45	22-090140-60-VK	1400	11.8	1924
1.05 dilna	18 60/45	33-090160-60-VK	1600	20.2	3157
1.05 dilna	18 60/45	33-090160-60-VK	1600	20.2	3157
1.05 dilna	18 60/45	33-090180-60-VK	1800	22.7	3551
1.02 dilna	18 60/45	22-090120-60-VK	1200	10.1	1649
1.02 dilna	18 60/45	22-090120-60-VK	1200	10.1	1649
1.06 opravna stroju	15 60/45	33-090120-60-VK	1200	15.1	2662
1.06 opravna stroju	15 60/45	33-090120-60-VK	1200	15.1	2662
1.06 opravna stroju	15 60/45	33-090100-60-VK	1000	12.6	2218