

Navrh otopnych teles

Akce : ZD Ostas - Zdar nad Metuji - objekt A
Datum : 23. 8.2022

Teplota topne vody - privodni : 60.0 oC
vratne : 45.0 oC
Procento vykonu pro navrh teles : 100.0

Vypis pro okruh c. 1

Mistnost cislo popis	Soustava teplota oC oC/oC	Otopne teleso --	vodni tepelny		
			delka mm	objem dm3	vykon W
1.01 kancelar	20 60/45	11-060110-60-VK	1100	3.4	615
1.01 kancelar	20 60/45	11-060110-60-VK	1100	3.4	615
1.01 kancelar	20 60/45	11-060100-60-VK	1000	3.1	559
1.01 kaneelar	20 60/45	11-060100-60-VK	1000	3.1	559
1.02 chodba	20 60/45	10-060070-60-VK	700	2.2	238
1.03 kancelar	20 60/45	11-060120-60-VK	1200	3.7	671
1.03 kancelar	20 60/45	11-060120-60-VK	1200	3.7	671
1.04 kuchynka	20 60/45	21-060070-60-VK	700	4.1	499
1.04 kuchynka	20 60/45	21-060070-60-VK	700	4.1	499
1.05 WC	20 60/45	21-060060-60-VK	600	3.5	427
1.06 chodba	20 60/45	11-060040-60-VK	400	1.2	224
1.07 satna	22 60/45	21-060090-60-VK	900	5.2	587
1.07 satna	22 60/45	21-060080-60-VK	800	4.6	522
1.08 umyvarna	24 60/45	33-060110-60-VK	1100	9.6	1211
1.09 chodba	20 60/45	11-060060-60-VK	600	1.9	336
1.10 WC	20 60/45	21-060140-60-VK	1400	8.1	997
1.11 sklad	15 60/45	10-060110-60-VK	1100	3.4	452
1.12 sklad	15 60/45	10-060040-60-VK	400	1.2	165
1.13 chodba	20 60/45	21-060080-60-VK	800	4.6	570
1.14 kuchyn	20 60/45	33-060080-60-VK	800	7.0	1058
1.15 jidelna	20 60/45	21-060140-60-VK	1400	8.1	997
1.15 jidelna	20 60/45	21-060140-60-VK	1400	8.1	997
1.15 jidelna	20 60/45	21-060140-60-VK	1400	8.1	997
1.15 jidelna	20 60/45	21-060140-60-VK	1400	8.1	997
1.16 pradelna	24 60/45	33-060080-60-VK	800	7.0	881
1.16 pradelna	24 60/45	33-060100-60-VK	1000	8.7	1101
1.17 sklad	20 60/45	33-060090-60-VK	900	7.8	1191